



DOUBLE DETECTOR CHECK SIZE	UTILITY VAULT CO. - MODEL NO.		BILCO - VAULT DOOR MODEL NO.
	VAULT WITH FIRE DEPT. CONNECTION	VAULT WITHOUT FIRE DEPT. CONNECTION	
4"	676-WA	577-WA	J-5AL
6"	687-WA	676-WA	J-5AL
8"	5106-LA	687-WA	JD-3AL
10"	5106-LA	5106-LA	JD-3AL

NOTES:

1. Finished grade shall slope away from the vault cover so as to prevent ponding around the cover.
2. This is to be a private facility, governed by *UPC*, *NFPA*, *Oregon Dept. of Human Services* and Fire Marshall, as applicable.
3. Vault door mechanisms shall not project below the ceiling of the vault interior.



City Of Beaverton

**ENGINEERING
DEPARTMENT**

PRIVATE FIRE SERVICE VAULT

UTILITIES ENGINEER
David A. Winship, P.E.

DATE
6 - 10 - 04

DRAWN BY
CDH - WD

DRAWING NO.
671